


Type 4 polyethylene cable pit

Cable pit







- Key

 ① Clear working dimension at pit base
 ② Clear working dimension at pit opening
 ③ Clear working dimension beneath rebate
 ④ Clear working dimension beneath riser cut off point
 ⑤ Height above retrorib

Type 4 polyethylene cable pit

Cable pit and riser

Description	Part No	Depth	Weight kg
Type 4 polyethylene pit	75957	800	12.0

Compatible lids and access covers

escription Part		Weight kg	
	No	${\bf cover}\ ^2$	total
Cement concrete lid (AS 3996 Cl A) - Blank 13	75979	21	21
Cement concrete lid (AS 3996 Cl A) - Communications 13	75983	21	21
Cement concrete lid (AS 3996 Cl A) - Electricity 13	75990	21	21
Steel lid (AS 3996 CI B) 1 4	70420	11	11
Steel lid (AS 3996 CI C) 14	custom	-	-
Steel PowerLok lid (AS 3996 CI B) 14	70430	14	14
Steel PowerLok lid (AS 3996 CI C) 14	custom	-	-
Steel Urbanfil recessed cover (AS 3996 CI B) ¹	80450	11	16
Steel Pavermate recessed cover (AS 3996 CI B) ¹	80451	11	17
Ductile iron Rhinocast recessed cover (AS 3996 Cl B) ¹	85037	28	49
Ductile iron Rhinocast solid top cover (AS 3996 CI B) ¹	85236	28	47

- 1. Refer to ACO Cablemate literature for details
- 2. Lifting weight kg 3. Lid dimension: 651 x 346 x 50 (mm)
- 4. Lid dimension: 650 x 345 x 48 (mm)

Specifications

General

The cable pit shall be ACO Cablemate Type 4 with lid/access cover* (see below) as manufactured by ACO Pty Ltd. or equal approved.

Materials

The pit body shall be manufactured from polyethylene with:

Electrical resistivity $1 \times 10^{16} \Omega / sq$ Flexural strength: 15MPa 0.31% Water absorption Frost proof Salt proof Dilute acid and alkali resistant Surface burn characteristics of the material shall comply with UL 723 IP ratings up to IP4X (AS 60529) enclosure protection against ingress

Polyethylene moulded pits feature a ribbed construction for strength and durability. The nominal clear opening shall be 605mm x 300mm. Units shall be manufactured with a clear depth of 745mm.

Lid/Access cover

The pit shall be covered with a cement concrete lid*, steel lid*, Urbanfil/ Pavermate access cover*, Rhinocast access cover* - see table opposite for compatible options.

Installation

The cable pit shall be installed in accordance with the manufacturer's installation instructions and recommendations.

* delete as applicable

ACO Limited New Zealand

Ph: 0800 448 080 www.aconz.co.nz sales@aconz.co.nz



© October 2020 ACO Limited. All reasonable care has been taken in compiling the information in this document. All recommendations and suggestions on the use of ACO products are made without guarantee since the conditions of use are beyond the control of the company. It is the customer's responsibility to ensure that each product is fit for its intended purpose and that the actual conditions are suitable. ACO Limited, pursues a policy of continuous product development and reserves the right to amend specifications without notice.